Certificate No.: LS250099GCC-0

Date of issue: 2025-08-21 Valid until: Indefinitely

Applicant: IMEON ENERGY

6 RUE DE KERBERNARD 29200 BREST FRANCE

**Device Type** Hybrid inverter (PV + DC coupled storage): **NEO {3.0~6.0} SH** 

Storage inverter: NEO {3.6~6.0} SR

Model(s): NEO {3.0~6.0} SH: NEO 3.0 SH, NEO 3.6 SH, NEO 4.0 SH, NEO 4.6 SH,

NEO 5.0 SH, NEO 6.0 SH;

NEO {3.6~6.0} SR: **NEO 3.6 SR, NEO 4.6 SR, NEO 6.0 SR** 

Trademark: IMEON ENERGY

**Technical data** Nominal active output power [W]: 3000 ~ 6000

Nominal output AC voltage [V]: 230V (L + N + PE, 50 Hz)

(For further details see A.2 Technical data of the power generating unit(s) on p.2)

**Software version** DSP1 V1.13; DSP2 V1.00

Applied standard(s) / EN 50549-1:2019 + A1:2023

guideline(s): Requirements for generating plants to be connected in parallel with distribution networks - Part 1-1: Connection to a LV distribution network -

Generating plants up to and including Type B

Certification scheme CMPD-01

**Test report no. HC24042503001-EG-EU-001** (2025-08-19)

The above-mentioned generating unit(s) are certified for type A generating modules.

This certificate confirms that the above-mentioned generating unit(s) with corresponding software meet the requirements of the referenced standard(s) / guideline(s) at the time of issuance of the certificate.

The generating units are considered to be compliant with the relevant articles (see Annex H, EN 50549-1:2019) of Commission Regulation (EU) 2016/631 of 14 April 2016 establishing a network code on requirements for grid connection of generators (NC RfG), provided that all settings as specified by the DSO and responsible party are complied with.

Further information on the assessment, including its scope and conditions, can be found in annex A.4 on p.4.

This certificate relates to type testing and does not imply LYNS's endorsement, approval, certification or on-going control of the product(s), either in terms of performance, design, manufacture or materials used. This certificate and the results stated herein relate solely to the sample product(s) tested and to the specific tests undertaken.

The certificate will remain valid for the stated period providing no changes are made to the product, production method etc. This certificate is only valid when this is also found at <a href="http://www.lyns-tci.com/en/certificate-search">http://www.lyns-tci.com/en/certificate-search</a> or contact Lyns-tci Technology Guangdong Co., Ltd..

This certificate is for the exclusive use of LYNS's Client and is provided pursuant to the agreement between LYNS and its Client. LYNS's responsibility and liability are limited to the terms and conditions of the agreement. LYNS assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned using this verification.

The certificate is comprised of 4 pages (including Annex of 3 pages).

Dongguan, 2025-08-21

ACCREDITED
Product Certification
Agency
PCA-159

Dipl.-Ing. Weizhao Zheng Head of certification body

Certification body Lyns-tci Technology Guangdong Co., Ltd. accredited according to ISO/IEC 17065 for product certification.



Annex to the Certificate No.: LS250099GCC-0

# A.1 Revision history of the certificate

Rev. No.	Date	Changes
Rev. 0	2025-08-21	Initial issue

### A.2 Technical data of the power generating unit(s)

Product family	NEO {3.0~6.0} SH/NEO {3.6~6.0} SR				
Model	NEO 3.0 SH	NEO 3.6 SH NEO 3.6 SR <sup>1</sup>	NEO 4.0 SH		
DC input (PV)		<u>.</u>			
Max. DC input voltage [V]	600				
Operating MPPT voltage range [V]	100 ~ 570				
Max. DC input current [A]	18 / 18				
Max. DC short circuit current [A]		22 / 22			
DC input (Battery)					
Battery voltage range [V]		90 ~ 430			
Nominal DC Voltage [V]		320			
Battery charging / discharging current [A]	max. 25 / 25				
AC input					
No. of phases	⊠ Single-phase	☐ Three-p	phase		
Nominal AC voltage [V]		230V (L + N + PE, 50 Hz)			
Max. intput AC current [A]	22.7	22.7	26.0		
AC output		<u>'</u>			
No. of phases	☐ Single-phase ☐ Three-phase		phase		
Nominal AC voltage [V]		230V (L + N + PE, 50 Hz)			
Max. output AC current [A]	13.0	15.7	17.4		
Nominal active output power [W]	3000	3600	4000		
Max. apparent output power [VA]	3300	3960	4400		
Backup / EPS		<u>.</u>			
No. of phases	⊠ Single-phase	☐ Three-p	phase		
Nominal output AC voltage [V]	230V (L + N + PE, 50 Hz)				
Max. output AC current [A]	13.0	15.7	17.4		
Nominal active output power [W]	3000	3600	4000		
Model	NEO 4.6 SH NEO 4.6 SR <sup>1</sup>	NEO 5.0 SH	NEO 6.0 SH NEO 6.0 SR <sup>1</sup>		
DC input (PV)		<u> </u>			
Max. DC input voltage [V]	600				
Operating MPPT voltage range [V]	100 ~ 570				
Max. DC input current [A]		18 / 18			
Max. DC short circuit current [A]	22 / 22				

<sup>1</sup> The models NEO 3.6 SR, NEO 4.6 SR and NEO 6.0 SR are Storage inverter , only have battery input parameter, no PV input parameter.



# Annex to the Certificate No.: LS250099GCC-0

DC input (Battery)				
Battery voltage range [V]	90 ~ 430			
Nominal DC Voltage [V]	320			
Battery charging / discharging current [A]	max. 25 / 25			
AC input				
No. of phases	⊠ Single-phase □ Three-phase			
Nominal AC voltage [V]		230V (L + N + PE, 50 Hz)		
Max. intput AC current [A]	26.0	32.6	32.6	
AC output				
No. of phases	⊠ Single-phase □ Three-phase		-phase	
Nominal AC voltage [V]	230V (L + N + PE, 50 Hz)			
Max. output AC current [A]	20.0	21.8	26.0	
Nominal active output power [W]	4600	5000	6000	
Max. apparent output power [VA]	5060	5500	6600	
Backup / EPS				
No. of phases	⊠ Single-phase □ Three-phase		-phase	
Nominal output AC voltage [V]	230V (L + N + PE, 50 Hz)			
Max. output AC current [A]	20.0	21.8	26.0	
Nominal active output power [W]	4600	5000	6000	
Operating temperature range	-20°C ~ +60°C			
Degree of protection	IP65 (according to EN 60529)			
Protection class	I (according to IEC 62109-1)			
Over voltage category	AC: III; DC: II (according to IEC 62109-1)			
Topology	No galvanic isolation			
Firmware version	DSP1 V1.13; DSP2 V1.00			
Manufacturer	IMEON ENERGY 6 RUE DE KERBERNARD 29200 BREST FRANCE			

# A.3 Remarks for type testing

Testing laboratory	LYNS-TCI TECHNOLOGY GUANGDONG CO., LTD.		
Room 1201, Unit 2, Building 18, No. 7, Science and Technolo Houjie Town, Dongguan City, Guangdong, 523960 P.R.C			
	(Accredited acc. ISO/IEC 17025: A2LA Accreditation no. 5200.02)		
Testing location	Same as above		
Measurement period	2024-04-25 ~ 2025-06-26		



Annex to the Certificate No.: LS250099GCC-0

### A.4 Conformity assessment

Based on the test results submitted, this certificate provides the following conformity assessment according to the specifications listed on the cover sheet:

	Electrical characteristics	Type testing performed	Assessment
4.4	Normal operating range	×	Compliant
4.5	Immunity to disturbances	⊠	Compliant
4.6	Active response to frequency deviation	×	Compliant
4.7	Power response to voltage variations and voltage changes	×	Compliant
4.8	EMC and power quality	×	Compliant
4.9	Interface protection	×	Compliant
4.10	Connection and starting to generate electrical power	×	Compliant
4.11	Ceasing and reduction of active power on set point	×	Compliant
4.12	Remote information exchange		Not applicable
4.13	Requirements regarding single fault tolerance of interface protection system and interface switch	×	Compliant